

**CITY of
SPRINGFIELD**



January 20, 1994

Mr. Don Petterson
Fred Miles Co.
1334 S. Glenstone
Springfield, MO 65804

RE: 566 S. Forest Ct.

Dear Mr. Petterson:

Personnel from this office dyed the building sewer line at the above address to determine whether it was connected to the City sewer system. After placing dye in the private sewer line and flushing with an adequate amount of water and waiting a sufficient amount of time, it appears that the private line is connected to the City's sanitary sewer system.

If we may be of further assistance, please do not hesitate to call 864-1923.

Yours truly,

Robert Corson
Water Pollution Control Inspector
Surveillance & Enforcement

RC/jb

566 S. Forest Ct.